

試驗報告

報告編號：TB-19-01691
C-19-04023

頁數：1 OF 1
報告日期：108年04月02日



工程名稱：自測
 承包商：-----
 委託單位：正源木業股份有限公司
 地址：高雄市林園區頂厝里過溝二巷53號
 供料廠商：-----
 樣品名稱：防焰合板(美耐皿板)
 送驗人員：正源木業股份有限公司-劉豐銘
 收件日期：108年03月18日
 試驗日期：108年03月18日~108年04月02日

此份資料僅供“送審使用”，不做其他用途。

- 備註：1.以上資料由顧客提供(收件及試驗日期除外)
 2.除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製
 3.下述報告內容標示#處由顧客提供
 4.本樣品由SGS材料暨工程實驗室-高雄(申請書號碼：KB-19-02536 C-19-05030，
 收件日期：108年03月14日)轉送至本實驗室執行本報告所示之試驗項目。

試驗結果：

試驗項目	試驗結果	CNS 7614(1994) 防焰一級規範值	CNS 7614(1994) 防焰二級規範值	CNS 7614(1994) 防焰三級規範值	試驗方法
防焰性					CNS 7614(1994) A法
火源加熱時間(sec)	10	-----	-----	-----	
餘焰時間(sec)	0.0	≤ 1	≤ 5	≤ 5	
餘燼時間(sec)	0.0	≤ 60	≤ 60	≤ 60	
炭化長度(cm)	2.9	≤ 5	≤ 10	≤ 15	

註：1.樣品平均厚度 17.6 mm

2.試驗者：陳彥融

3.測試面為正面

4.本試驗之樣品厚度不在TAF認證範圍內，故無法出具TAF標誌之報告。

此份資料僅供“送審使用”，不做其他用途。

報告簽署人

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

試驗報告



報告編號：KB-19-01746

C-19-03607

頁數：1 OF 2

報告日期：108年03月14日



委託單位：正源木業股份有限公司
 地址：高雄市林園區頂厝里過溝二巷53號
 樣品名稱：防焰合板(美耐皿板)
 送驗人員：正源木業股份有限公司(劉豐銘)
 收件日期：108年02月21日
 試驗日期：108年02月21日~108年03月14日
 試驗方法：JIS Z2801
 備註：1.以上資料由顧客提供(收件及試驗日期除外)
 2.除非另有說明，此報告結果僅對測試之樣品負責

此份資料僅供“送審使用”，不做其他用途。

試驗結果：

試驗菌種：金黃色葡萄球菌 Staphylococcus aureus ATCC 6538P			
試驗組別	CFU/cm ²	LOG	抗菌值(R)
對照組 0 小時菌數(U ₀)	1.3×10 ⁴	4.11	> 3.61
對照組 24 小時菌數(U _t)	2.6×10 ³	3.41	
樣品組 24 小時菌數(A _t)	<0.63	-0.20	

試驗菌種：大腸桿菌 Escherichia coli ATCC 8739			
試驗組別	CFU/cm ²	LOG	抗菌值(R)
對照組 0 小時菌數(U ₀)	1.1×10 ⁴	4.04	> 6.24
對照組 24 小時菌數(U _t)	1.1×10 ⁶	6.04	
樣品組 24 小時菌數(A _t)	<0.63	-0.20	

試驗菌種：綠膿桿菌 Pseudomonas aeruginosa ATCC 9027			
試驗組別	CFU/cm ²	LOG	抗菌值(R)
對照組 0 小時菌數(U ₀)	6.4×10 ³	3.80	> 5.76
對照組 24 小時菌數(U _t)	3.7×10 ⁵	5.56	
樣品組 24 小時菌數(A _t)	<0.63	-0.20	

----- 1 -----

此份資料僅供“送審使用”，不做其他用途。

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準


 報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料暨工程實驗室-高雄

試驗報告



報告編號：KB-19-01746

C-19-03607

頁數：2 OF 2

報告日期：108年03月14日

試驗方法：JIS Z2801

試驗結果：

試驗菌種：抗藥性金黃色葡萄球菌 MRSA ATCC 33591			
試驗組別	CFU/cm ²	LOG	抗菌值(R)
對照組 0 小時菌數(U ₀)	1.1×10 ⁴	4.04	> 4.14
對照組 24 小時菌數(U _t)	8.9×10 ³	3.94	
樣品組 24 小時菌數(A _t)	< 0.63	-0.20	

註：

U₀: 無加工樣品接種後立即測試之菌數，其應介於 6.2×10³~2.5×10⁴ CFU/cm²。

U_t: 無加工樣品經 24 小時培養後之菌數。

A_t: 加工樣品經 24 小時培養後之菌數。

抗菌值 (R) = U_t - A_t; 抗菌活性值 (R) 若 ≥ 2.0，表示有抗菌效果。

若無“無加工樣品”，以空白組代替之。

抗菌試驗委由台灣檢驗科技股份有限公司高雄食品實驗室檢測。(報告編號：VO/2019/20097)

----- oOo -----



此份資料僅供“送審使用”，不做其他用途。

本報告若有提供規範值，該規範值僅供參考，合格之判定以委託單位實際要求為準

許 慧 貞
報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.